

UHM Water Safety Group

**HIGH RISK WATER SAFETY AREAS**

CLINICAL DIVISION	CLINICAL AREA (Royal)	LEGIONELLA TESTING REQUIRED 12 monthly	PSEUDOMONAS TESTING REQUIRED 6 monthly
<b>Medicine</b>	Ward 117 Infectious Diseases	YES	NO
	Ward 122 Respiratory Ward	YES	NO
	Ward 222 Respiratory Ward/NIV Unit	YES	NO
	Ward 233 Respiratory Ward	YES	NO
	Ward 201 Haematology / Oncology In- Patients	YES	YES
	Ward 202 Haematology / Oncology Day Patients	YES	NO
	Hemodialysis Renal Day Patients	YES	NO
	Ward 124 Renal In-Patients	YES	YES
	<b>Surgery</b>	Critical Care Unit (Pod 3-6)	YES
Special Surgical Care Unit		YES	YES
CTS (Burns Clinic)		NO	YES
<b>Specialised</b>	Critical Care Unit (Pod 1-2)	YES	YES
<b>CWD</b>	Ward 215 Paediatric Intensive Care Unit	YES	YES
	Paediatric Oncology Day Unit (located next to Ward 216)	YES	NO
	Paediatric ward 216 (CF in-patients)	YES	NO
	Paediatric ward 217 (Oncology in-patients)	YES	YES

	Paediatric Out-Patients (CF patients)	YES	NO
	Neonatal Intensive Care Unit	NO	YES
	Neonatal High Dependency Unit	NO	YES
	Special Care Baby Unit	NO	YES
<b>CLINICAL DIVISION</b>	<b>CLINICAL AREA (County)</b>	<b>LEGIONELLA TESTING REQUIRED 12 monthly</b>	<b>PSEUDOMONAS TESTING REQUIRED 6 monthly</b>
<b>Medicine</b>	Hemodialysis Renal Day Patients	YES	NO
	Chemotherapy Day Unit	YES	NO
	Ward 12 Respiratory Ward	YES	NO
<b>Surgery</b>	Critical Care Unit	YES	YES

13:07:17

**Note:**

As per the Water Safety SOP -

All of the above clinical areas are high risk water safety areas and require daily water flushing of little used water outlets for at least 2 minutes.

All other areas (not listed above) require water flushing of little used water outlets at least every other day (3 times per week) for at least 2 minutes.

Any queries please contact the Infection Prevention Team on extension 76360

**Clinical Divisional Representatives on the Water Safety Group:**

<b>Division</b>	<b>Representative</b>
Medical Division	
Surgical Division	
Specialised Division	
Childrens, Womens & Diagnostics Division	